



CERTIFICATE OF ANALYSIS

FSA

Analysis Results of a Weighted Average Sample

Collection Method

Sample
Composite

Sample Received

3/11/2013 8:05:00AM

Sample Reported

3/11/2013 8:18:05AM

CHEMICAL ANALYSIS

As	76.4 ppm
Color	80 APHA
H ₂ SiF ₆	24.38 %
HF	0.78 %
Vessel ID	TILX-110360
SPGV	1.241
TPA	0.2477 %
Temperature	72 f
Pb	33.2 ppm



Certified to
NSF/ANSI 60

Hydrofluosilicic Acid
Commercial Grade
The Mosaic Company
Uncle Sam, LA 70792

Chad Basso / QC Lab Manager

This product meets AWWA Standard B703a-08
Maximum use for potable water 6.0 mg/Liter